

Confined Space Safety Assessment



SECTION 1: Information						
Confined Space ID:	Salt Water Strainer		Developed By:	Tighe & Bond		
Asset ID:	CSSA-11		Origin Date:	July 2019		
Building:	Salt Water Pump House		Revision #	0		
Entry Location:	At top of vessel		Revision Date:	-		
Entry Purpose:	Repair and Maintenance					
SECTION 2: Confined Space Determination						
If needing to enter an enclosed space, indicate which of the following apply:					Yes	No
1. Is the space large enough and so configured that you can bodily enter and perform work?					X	
2. Does the space have limited or restricted means for entry or exit? (Would it be difficult to exit the space through a standard door, ramp, or OSHA-compliant stairs?)					X	
3. Is the space intended for continuous employee occupancy? (Is the space equipped with HVAC, desk, phone, lighting, or other typical comforts of continuous occupancy)						X
<p style="text-align: center;"><i>If you have checked <u>ANY</u> of the highlighted boxes, you <u>DO NOT</u> have a confined space. Otherwise, you have a Confined Space.</i></p>						
Does this space meet the definition of a Confined Space?					Yes	
SECTION 3: Assessment of Atmospheric Hazards						
Atmospheric Hazard	Actual or Potential Hazard?		Can it be Eliminated?		Means to Eliminate Atmospheric Hazard	
	Y	N	Y	N		
Oxygen Deficiency		X				
Flammable Gas or Vapor		X				
H ₂ S (Hydrogen Sulfide)		X				
CO (Carbon Monoxide)		X				
Other Toxic Gas (Specify below):		X				
<p style="text-align: center;"><i>If you have <u>ONLY</u> checked shaded boxes in Section 3 and Section 4, you do not have a permit required confined space. Stop completing this form, and you may enter without a permit. Otherwise, continue completing this form.</i></p>						
SECTION 4: Assessment of Serious Safety Hazards						
Hazards which are immediately dangerous to life or health or would impair your ability to perform a self-rescue						
Serious Safety Hazards	Actual or Potential Hazard?		Serious Safety Hazards	Actual or Potential Hazard?		
	Y	N		Y	N	
Engulfment Hazard	X		Other Serious Safety Hazard			
Trapping Hazard		X	Moving Parts or Agitator	X		
Converging walls		X	Steam or Extreme heat/cold		X	
Tapered floor		X	Shock or Electrocutation		X	
Sloping floor		X	Other (Specify):			
Means to Eliminate Engulfment and Other Serious Safety Hazards			Drain Vessel. Follow Hazardous Energy Isolation (Lockout/Tag-out) Procedures for equipment associated with the space listed above. Remove auger from tank.			
Means to Eliminate Trapping Hazards						
<p style="text-align: center;"><i>If you have <u>ONLY</u> checked shaded boxes in Section 3 and Section 4, you do not have a permit required confined space. Stop completing this form, and you may enter without a permit. Otherwise, continue completing this form.</i></p>						
Does this space meet the criteria for a non-Permit Confined Space?					No	

Confined Space Safety Assessment



SECTION 5: Assessment of Other Safety Hazards

Other Safety Hazards	Actual or Potential Hazard?		Can it be Eliminated?		Means to Eliminate Safety Hazard
	Y	N	Y	N	
Eye / Skin Hazard		X			
Mechanical Hazard	X				Remove auger from tank.
Heat/Cold Stress		X			
Hot/Cold Surfaces		X			
Space Configuration		X			
Egress / Access	X		X		Personnel are required to enter through the top of the tank. Use ladder to enter. Use caution.
Slippery Surfaces		X			
Elevated Work (Falls)		X			
Other (Specify below):		X			

SECTION 6: Entry Classification

Reclassification Assessment	Yes	No
1. Is there an actual or potential atmospheric hazard (Section 3) – Even if controlled?		X
2. Can all Serious Safety Hazards (Section 4) be eliminated without entry?	X	
3. Can all Other Safety Hazards (Section 5) be eliminated without entry?	X	

If you have checked ONLY shaded boxes, you can reclassify the space as a non-permit required confined space. Stop completing this form, and you may enter without a permit.

Can this space be reclassified to a non-Permit Confined Space?

Yes

Permit Required Confined Space?

No

Should any planned or unplanned activities or hazards occur which are not listed above, such as welding, cutting, chemical usage, etc. would require a reassessment of the of the space prior to entry.

SECTION 7: Photo(s)

